

ENTERGY NEW ORLEANS, INC.
CITY OF NEW ORLEANS
Docket No. UD-16-02

Response of: Entergy New Orleans, Inc.
to the Eighth Set of Data Requests
of Requesting Party: Alliance for Affordable
Energy

Question No.: AAE 8-21

Part No.:

Addendum:

Question:

Provide any studies regarding the sufficiency of reactive power in the DSG load pocket for both the current period and future periods.

Response:

The sufficiency of reactive power in DSG is analyzed every year during the Company's annual reliability assessment. The annual reliability assessment is performed in accordance with the requirements detailed in the NERC TPL 001-4 reliability assessment to ensure that the Company's transmission grid is compliant with the NERC reliability standard. Please see the Company's response to AAE 8-11 for the Company's recent annual reliability assessment reports.